

# CITY OF SAUSALITO

## Addendum No. 5

Notice Issued April 3, 2014

### For: Sausalito Fishing Pier Repair Project

#### NOTICE TO ALL CONTRACTORS SUBMITTING BIDS FOR THIS WORK:

You are hereby notified of the following information, changes, clarifications or modifications to the original Contract Documents, Project Manual, Drawings, Specifications and subsequent Addenda. The Addendum shall supersede the original Contract Documents and previous Addenda wherein it contradicts the same and shall take precedence over anything to the contrary therein. All other conditions remain, UNCHANGED.

This Addendum is hereby made a part of the Contract Documents to the same extent as though it was originally included therein.

#### Clarifications:

- 1) Top and bottom surface of wood beams, joists and decking shall be surfaced.
- 2) (N) 2 x 6 Pony Wall shall be Cedar.
- 3) Sheet S0.0,
  - a. 06000 Wood Note 1 shall be revised **FROM** Pressure Treated Douglas Fir **TO** Cedar.
  - b. 06000 Wood Note 6 shall be revised **FROM** 1/8" **TO** 3/16".
- 4) Sheet D1.1

Change drawing callout **FROM** "Existing wood decking to be removed and replaced per owners confirmation, wood framing below to be replaced" **TO** "Existing wood decking to be removed and reused, wood framing below to be replaced".

**END OF ADDENDUM NO. 5**

#### ACKNOWLEDGED

\_\_\_\_\_  
Bidder's Signature

A signed copy of this addendum is to be submitted as a part of the bid package for the subject project. Failure to do so may subject the Bidder to Disqualification.